



Westenergie AG - Eurotest

Test report

No.: 20_389-4

Version: 1/1

Customer : Hauff-Technik GmbH & Co. KG
Robert-Bosch-Str. 9
89568 Hermaringen

Test object : Earthing wall bushing

Type : HEA W M12

Manufacturer : Hauff-Technik GmbH & Co. KG

Date of receipt : 01.02.2021

Date of test : 10.02.2021

Applied test regulations : - By prescription of the manufacturer
- According to DIN EN 50522 (VDE 0101-2):2011-11, Annex D

Test carried out : Short circuit tests on an earthing wall bushing with 10 kA/1 s

Test result : The earthing wall bushing, type HEA W M12 of the manufacturer Hauff-Technik GmbH & Co. KG **passed** the short circuit tests with 10 kA/1 s by prescription of the manufacturer according to DIN EN 50522 (VDE 0101-2):2011-11, Annex D. The maximum allowed temperature of 300 °C was not reached. No damage was visible at the test object after the tests.

Specialist testers : Alexander Herbst; Ahmet Karakavak; Christoph Pieper

Dortmund, 12.03.2021

Dr.-Ing. Dirk Borneburg
Manager test laboratory

Dipl.-Ing. Holger Walter
Test engineer

Report No. 20_389-4 contains 8 pages and 3 annexes.

Test results in this report are only valid for the tested objects. A partly duplication or publication is not allowed without written permission by Westenergie AG, Eurotest. The authenticity of this report is only ensured with Eurotest-coinage on the first page.

Summary

The Westenergie AG, Eurotest carried out short circuit tests with 10 kA/1 s on an earthing wall bushing manufactured by Hauff-Technik GmbH & Co. KG by prescription of the manufacturer according to DIN EN 50522 (VDE 0101-2):2011-11, Annex D.

Result:

The earthing wall bushing, type HEA W M12 of the manufacturer Hauff-Technik GmbH & Co. KG **passed** the short circuit tests with 10 kA/1 s by prescription of the manufacturer according to DIN EN 50522 (VDE 0101-2):2011-11, Annex D. The maximum allowed temperature of 300 °C was not reached. No damage was visible at the test object after the tests.

Contents:

Page:

1. Applied test regulations.....	4
2. Technical data of the test object	4
3. Test and measuring equipment.....	5
4. Tests carried out and results	6
5. Overall result	8

Annex:

01 Data sheet of the test object	(1 page)
02 Current -/time-diagrams	(2 pages)
03 Temperature-/time-diagrams	(1 page)

1 Applied test regulations

By prescription of the manufacturer according to

DIN EN 50522 (VDE0101-2):2011-11

Earthing of power installations exceeding 1 kV a.c.;

German version EN 50522:2010

Prescription of the manufacturer:

- Short circuit test with 10 kA/1 s
- Maximum allowed temperature: 300 °C
- No visible damage

2 Technical data of the test object

Test object: Earthing wall bushing
Type: HEA W M12
Manufacturer: Hauff-Technik GmbH & Co. KG
Concrete block: WU – concrete C 25/30

3 Test and measuring equipment

Equip.-No.	cal.	Equipment	Type	Manufacturer
ET-811	*	Fibre Optic Isolated Digitizing Sub-system	GEN7t	HBM
ET-533		50 kA high-current test equipment	GDPN 5000/12 Sp	SIEMENS
ET-651	*	Digitizing Oscilloscope	DL750	Yokogawa
ET-556	*	Digital sampling microhmeter	DSM 200	T&R Test Equipment Limited
ET-1025	*	High current measurement system	HSM-S	RWE Eurotest GmbH

*) Measuring equipment is calibrated based on national and international reference standards. Calibration certificates can be inspected on request.

Table 1: Test and measuring equipment

The measurement uncertainty of the measuring instruments has been calculated and is archived by Eurotest. Documents can be inspected on request.

4 Tests carried out and results

The Westenergie AG, Eurotest carried out short circuit tests with 10 kA/1 s on an earthing wall bushing manufactured by Hauff-Technik GmbH & Co. KG by prescription of the manufacturer according to DIN EN 50522 (VDE 0101-2):2011-11, Annex D.

The test objects were connected with 240 mm² copper cables to the test transformer. One cable was connected to the earthing bushing, 1 cable was connected to a flat steel angle, mounted in the cross connector.



Figure 1: Test setup

The temperatures of the test objects were measured with 0,5 mm NiCr-Ni-Thermocouples (See figure 2). The measuring points were: T01 at the core material, T02 at the shrink sleeve, T03 at the loose flange and T04 at the cross connector.




Figure 2: Positions of the thermocouples

The results of the short circuit tests are given in table 3.

Test	I_{RMS} [kA]	t [s]	I^2t [MA ² s]	Maximum measured temperatures [°C]			
				T01:	T02:	T03:	T04:
1	10.35	1.005	107.6	142.8	26.3	14.9	44.3
2	10.33	1.004	107.1	161.6	34.3	22.5	55.1


Table 3: Results of the tests

The maximum allowed temperature of 300 °C was not reached during the short circuit tests.

5 Overall result


The earthing wall bushing, type HEA W M12 of the manufacturer Hauff-Technik GmbH & Co. KG **passed** the short circuit tests with 10 kA/1 s by prescription of the manufacturer according to DIN EN 50522 (VDE 0101-2):2011-11, Annex D. The maximum allowed temperature of 300 °C was not reached. No damage was visible at the test object after the tests.


- End of report -



Maßstab: 1:5 hauff-technik Semierung: HEA-W-M12/X Zusammenstellung		Zeichnungsnummer: 8270023000 Ersatz für: 03/124/00
Blatt 1 von 1	Datum: 2018-02-20 Erstellt: 2018-02-20 Gepr.: Norm:	
Zustand: Änderungsteil Datum: Von: Status: In Arbeit		
Freibleibenz nach		


Current-/time-diagrams





Temperature-/time-diagrams

Test 1



Test 2

